

# Klear Sight™

REFRIGERATOR  FREEZER DOOR

## Exterior View



## Benefits

### Visibility in your walk-in:

- Encourages cleanliness and organization
- Consistent viewing by management and inspectors
- Allows kitchen staff to view product and inventory before entry
- Enhances security from theft, sabotage and employee non-production and unauthorized activities
- Enhances safety allowing view of incapacitated or injured persons

### Klear Sight in lieu of Plexiglas adds the benefits of:

- Allowing the same benefits to your Freezer as in your Cooler
- Provides more insulation value
- Additional strength to eliminate warping
- Easily cleanable with normal cleaning solutions
- 36" x 84" clear door opening

## Interior View












For more Information call  
888-478-8600  
[www.koolstar.com](http://www.koolstar.com)



# Klear Sight™

REFRIGERATOR  FREEZER DOOR

Entry door shall be Klear Sight door, opening 36" x 84"

-  Viewing area shall be 24" x 48"
-  Tempered Safety Glass, minimum 3 panes hermetically sealed glass
-  Freezer doors and high humidity conditions require heated glass
-  Protruding kick plate bumper at door bottom
-  2 Hinges      35-0082001
-  1 Hinge      35-0082000
-  Door pull      35-0120002
-  Dead bolt      35-0159445
-  Door closer      35-01786K

## Specifications:

Klear Sight Door opening size shall be 36" wide by 84" high. Viewing area of door shall be 24" x 48" and shall be full door thickness; minimum 3 panes tempered safety glass. Freezer doors shall have heated glass. Doors shall be flush; infitting style constructed of fiberglass reinforced plastic door perimeters and jamb. Metal, vinyl and PVC frames are not acceptable. Doors and door frame shall have 1 ½" steps, providing an airtight flush fit. Doors shall be insulated with a full four inches (4") thick core of same insulation materials specified for the wall panels. Doors shall be finished with stainless steel interior and exterior. Each door shall be provided with a three-sided snap-in magnetic gasket and sweep gasket to seal the bottom of the door. Doors shall be mounted with two 7" strap cam lift hinges and one 5" strap cam lift hinge, one door pull, one pinion shaft door closer in compliance with the Grade 1 requirements of ANSI standard A156.4. 6" high impact bumper, protruding 7/8" off face of door shall be mounted between bottom hinge and viewing area. Freezer door jamb shall be provided with four sided heater cable with a stainless steel threshold and one heated air vent to equalize pressure between the interior compartment and exterior spaces.

For more Information call  
888-478-8600  
[www.koolstar.com](http://www.koolstar.com)